






Residential Room Air Refrigerators Conditioners Energy efficiency benefits from residential refrigerators and room air conditioners with the implementation of Minimum Energy Performance Standards at two levels of ambition (minimum and high) as detailed in the United Nations Environment Programme (UNEP) United For Efficiency (U4E) Model Regulation Guidelines.

ANNUAL SAVINGS IN 2030*

4	Reduce electricity use by over 1.1 TWh which is 9.5% of current national electricity use
1	Save electricity worth 330 Million US\$
	equivalent to over 2 Power Plants [100MW each]
	Reduce electricity CO ₂ emissions by over 360 Thousand tonnes

equivalent to 200 Thousand Passenger Cars

EVEN GREATER SAVINGS POSSIBLE WITH MORE STRINGENT REGULATION



DETAILED BENEFITS




ANNUAL SAVINGS IN 2025, 2030 AND 2040*

		Residential Refrigerators			Room Air Conditioners			
		2025	2030	2040	2025	2030	2040	
4	Electricity (GWh)	86	190	380	460	930	1,700	
<u>4</u>	Electricity Bills (Million US\$)	25	55	110	130	270	490	
	CO2 Emissions (Thousand tonnes)	28	61	120	150	300	550	

CUMULATIVE SAVINGS BY 2030 AND 2040*

		📄 Residenti	al Refrigerators	Room Air	Conditioners
		2030	2040	2030	2040
4	Electricity (TWh)	1.0	4.0	5.1	19
<u>4</u>	Electricity Bills (Billion US\$)	0.3	1.2	1.5	5.6
	CO2 Emissions (Million tonnes)	0.3	1.3	1.6	6.2

CONTRIBUTION TO CUMULATIVE ELECTRICITY USE BY 2040



■ Residential refrigerators ■ Room air conditoners

Country Data and Input Assumptions



GENERAL INFORMATIC	N	ELECTRICITY MARKET	ELECTRICITY MARKET		
Population	29.5 Million	Residential Electricity tariff	0.29 US\$ / kWh		
GDP per capita	2,202 US\$	Transmission and	22.6%		
Electrification level	97.6%	distribution loss factor			
CO2 Emission Factor	0.25 kg / kWh				

ASSUMPTIONS

Unit Energy Consumption	(kWh/year) or Efficiency Level
-------------------------	--------------------------------

	Product	Business As Usual	Minimum Ambition Scenario	High Ambition Scenario	Type of Product
0	Residential Refrigerators	340	247	123	2-door refrigerator-freezer of average size 210 liters
	Room Air Conditioners	3,717	2,406	1,776	A mix of 3.5 kW and 7 kW split units with a weighted-average cooling capacity of 5 kW

METHODOLOGY

The analysis uses the UNEP-U4E's Country Savings Assessment Models to estimate the impacts of implementing policies that improve the energy efficiency of new household air conditioners and refrigerators. The savings potential in each scenario assumes Minimum Energy Performance Standards (MEPS) are introduced in 2020 at two different levels of ambition (minimum and high) as shown above.

ASSUMPTIONS AND DATA SOURCES

Market size was estimated by household ownership forecasts derived from population, climate, and macroeconomic indicators as described below. This data was validated by comparison with data from industry partners; the UN COMTRADE database and other market research.

- Population (2019 and future forecasts) comes from the UN Population Division.
- GDP per capita data (2018) comes from the World Bank with future growth forecasts derived from the IPCC's SSP3 scenario.
- Cooling Degree Days are based on average monthly temperatures from weatherbase.com, degreedays.net or given by wunderground.com.

Current total electricity consumption comes from the World Bank and the US Energy Information Administration (EIA) with future forecasts derived from the

- International Energy Agency's (IEA) World Energy Outlook 2018. Residential electricity tariffs are based on IEA data.
- = Transmission and distribution loss factor is a regional average calculated from electricity production and consumption data published by the IEA.
- Electrification levels come from the IEA's Word Energy Outlook 2018 and the World Bank.
- CO2 emission factors come from the IEA and the Institute of Global Environmental Strategies (IGES) and are assumed constant in future years.
- Product typical characteristics are based on analysis from the UNEP-U4E Model Regulation Guidelines and other data from UNEP-U4E industry partners and technical experts including the US Lawrence Berkeley National Laboratory (LBNL) and GIZ.
- The approach of calculating the potential direct emissions saving of refrigerators and air conditioners is based on expert input from GIZ and LBNL.
- Additional to the above sources, a questionnaire was used to gather data from country officials.
- In a small number of instances, additional data was obtained from internet research or by using proxy data from similar markets.

Further details of the modelling approach and assumptions are available on the U4E website. For more information contact: U4E@un.org













